

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40

RESOLUTION NO. 7745

A RESOLUTION introduced by City Manager Neil Dobler relating to and authorizing Project No. 29095 which provides for the correction of inflow and infiltration into the City's sanitary collection system, as more specifically described herein.

BE IT RESOLVED by the Council of the City of Topeka, Kansas, that it finds the following described public improvement to be necessary and in the public interest and does hereby authorize Project No. 29095 with a project budget summarized herein and more fully set forth on the attachment hereto:

A. GENERAL NATURE OF IMPROVEMENT:

Provides for the correction of inflow and infiltration into the City's sanitary collection system. Currently, combined dry weather flow at the North Topeka Waste Water Treatment Plant and the Oakland Waste Water Treatment Plant is 18 million gallons per day (MDG). Wet weather flow, depending on the magnitude of the storm event, can approach 90 million gallons per day. The increase in flow during wet weather is caused by inflow and infiltration of storm water into the sanitary sewer system.


B. ESTIMATED OR PROBABLE COST:

\$700,000.00

C. APPORTIONMENT OF COSTS:

Combined water, wastewater, and stormwater utility operating funds and all other lawfully available funds.

ADOPTED and APPROVED by the City Council JAN 24 2006.



ATTEST:

Iris E. Walker  
Iris E. Walker, City Clerk

William W. Bunten  
William W. Bunten, Mayor

APPROVED AS TO FORM AND LEGALITY  
DATE 12/14/05 BY BBC