



- NOTES:
- STEPS SHALL BE INSTALLED IN ALL INLETS OVER 4' DEEP AND LOCATED UNDER MANHOLE RING AND COVER.
 - SUPPLIERS SHALL GRIND ALL BURRS SMOOTH ON CASTINGS.
 - THE INLET TOP SHALL SIT SQUARELY ON TOP OF THE INLET BOTTOM SECTION. THE INLET WALLS SHALL NOT BE OFFSET MORE THAN ONE INCH BETWEEN TOP AND BOTTOM SECTIONS.

NO.	DATE:	REVISION	BY:	APP'D
2	Dec. 2009	Added #4 bar to PLAN & 3. to NOTES	DHS SB	
1	Feb. 2008	Mod. MH Cover	DHS SB	

DRAWN BY: *rm/mc*
APP'D BY: *R. Cloutier*



**SHAWNEE COUNTY, KANSAS
PUBLIC WORKS DEPARTMENT**
1515 HW SALINE
TOPEKA, KS 66618
(785) 233-7702



STANDARD DETAILS

TYPE I-P INLETS
(PRECAST)
(DT-010)

DATE: Month Year
SHEET: X_of_X
PROJ: X-XXXXXX.XX